

Mob. : 098962-23479

# A.B. FIRE SAFETY

Supplier & Contractor of All Type of Fire Fighting Equipments, Extinguishers & Safety Equipments

H.No. 45, Gali No. 2, Virat Nagar, Phase II, Model Town, Panipat

Ref. No. .... 1851 .....

सर्विस पत्र

यह सर्विस पत्र दिया जाता है कि मैसर्स *Smt Kabani Devi Lohia Public School - Lehna Marg - Bahadurpur (K.R.)* के प्रतिष्ठान में भेरे द्वारा दिये गये अग्निशामन यन्त्र और किया गया रिफिलिंग कार्य उपयुक्त और संतोषजनक स्थिति में है। अतः वर्ष 2026-2027 के लिये उपयुक्त सर्विस पत्र दिया जाता है।

नोट : कृपया रिफिलिंग के लिये Due Date से 15 दिन पहले अवश्य सम्पर्क करें।

निम्नलिखित :-

1. सी.ओ.डू. कि.ग्राम
2. ऐ.बी.सी. 7+2 कि.ग्राम 6
3. मेकैनिकल फोम X कि.ग्राम
4. कुल 9

Date- 27-2-2026  
Due- 26-2-2027

For A. B. FIRE SAFETY

Prop.

To M/s JAIRAM SHIKSHAN SANSTHAN  
LOHAR MAJRA DISTRICT KURUKSHETRA  
Memo No. FS/2025/1435 dated : 13/10/2025

**Subject :** Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at Plot Area 91054.260 Sq. Mtrs. VILLAGE LOHAR MAJRA DISTRICT KURUKSHETRA of JAIRAM SHIKSHAN SANSTHAN :

Reference your Transaction Id 110682523000015 dated: 11/08/2025 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Thanesar. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

<b>Tower Name</b>	<b>Floor Detail</b>	<b>Terrace Height of Last Livable Floor(In Meters)</b>	<b>Ground Coverage</b>
SETH NAVRANG RAI LOHIYA JAIRAM GIRLS COLLEGE	GROUND + 2 FLOOR	12 Mtrs.	35851.07 Sq. Ft.
SMT KESARI DEVI LOHIYA JAIRAM PUBLIC SCHOOL	GROUND + 1 FLOOR	08 Mtrs.	36184.62 Sq. Ft.
JAIRAM SAINIK SCHOOL BOYS HOSTEL	GROUND + 1 FLOOR	08 Mtrs.	31081.87 Sq. Ft.
JAIRAM SAINIK SCHOOL GIRLS HOSTEL	GROUND + 1 FLOOR	08 Mtrs.	9879.70 Sq. Ft.
CANTEEN	GROUND FLOOR	04.5 Mtrs.	5415.03 Sq. Ft.
TEMPLE	GROUND FLOOR	04 Mtrs.	456.62 Sq. Ft.
CHAIRMAN OFFICE	GROUND FLOOR	04 Mtrs.	1048.66 Sq. Ft.
AUDITORIUM HALL	GROUND FLOOR	06.5 Mtrs.	14366.98 Sq. Ft.
<b>Tower Name</b>	<b>Basement Level</b>	<b>Basement Area</b>	<b>Basement Remarks</b>
	Nil	Nil	

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

**Remarks:- ok**